

Měrná spotřeba tepla na vytápění (GJ/m<sup>2</sup> otápné plochy)

Za rok 2013

	OznaceniVS	č.p.	Spotřeba GJ	otápné plocha m <sup>2</sup>	GJ/m <sup>2</sup>
Jungmannova	KO05	1232	241,1	526,70	0,458
Jungmannova	KO06	1308	190,9	453,31	0,421
Mezi Mlaty	VS01	1105	307,2	455,40	0,675
	VS01	1106	295,8	455,40	0,650
	VS01	1107	178,2	455,40	0,391
	VS01	1108	182,8	455,40	0,401
	VS01	1109-10	248,0	889,50	0,279
	VS01	1111-12	199,0	903,20	0,220
	VS01	1113-14	679,9	1 577,26	0,431
	VS01	1115-16	482,8	917,68	0,526
	VS01	1117	211,4	458,80	0,461
	VS01	1118	213,9	464,08	0,461
	VS01	1119	287,8	458,80	0,627
	VS01	1120	254,9	406,34	0,627
	VS01	1121-22	257,5	913,48	0,282
	VS01	Školka	163,3	753,00	0,217
			<b>3 962,5</b>	<b>9 563,74</b>	<b>0,414</b>
Kollárova	VS02	284	535,5	1 739,70	0,308
Kollárova	VS02	285	583,5	1 739,70	0,335
Kollárova	VS02	286	553,3	1 739,70	0,318
Kollárova	VS02	287	602,5	1 739,70	0,346
Jungmannova	VS02	220	266,0	936,00	0,284
Jungmannova	VS02	221	131,0	818,00	0,160
Kollárova	VS02	222	198,0	931,00	0,213
Kollárova	VS02	223-5	580,6	2 274,91	0,255
Jungmannova	VS02	1248	335,4	853,60	0,393
			<b>3 785,8</b>	<b>12 772,31</b>	<b>0,296</b>
Brandlova	VS03/1	92	344,2	2 027,69	0,170
Brandlova	VS03/2	93	581,5	2 027,69	0,287
Brandlova	VS03/3	94	556,1	2 027,69	0,274
Tyršova	VS03/4	142	414,8	1 899,90	0,218
Tyršova	VS03/5	143	781,0	1 899,90	0,411
Tyršova	VS03/6	144	678,7	1 899,90	0,357
Za Stadionem	VS05	1145-46	362,2	1 212,00	0,299
	VS05	1147-48	381,0	1 319,00	0,289
	VS05	1149-50	375,0	1 319,00	0,284

	VS05	1151-52	387,0	1 319,00	0,293
	VS05	1153-54	405,0	1 319,00	0,307
	VS05	1155-56	410,0	1 319,00	0,311
	VS05	1157-58	389,9	1 263,92	0,308
	VS05	1159-60	276,5	1 263,94	0,219
	VS05	1161-62	413,0	1 319,00	0,313
	VS05	1163-64	382,0	1 319,00	0,290
	VS05	1165-66	431,0	1 319,00	0,327
	VS05	1167-68	387,0	1 319,00	0,293
			<b>4 599,6</b>	<b>15 610,86</b>	<b>0,295</b>
Švabinského	VS06	1136-38	680,4	2 049,05	0,332
Švabinského	VS06	1139-41	757,2	2 007,50	0,377
Švabinského	VS06	1142-44	539,3	2 007,50	0,269
Strážovská	VS07	1311	531,5	1 739,70	0,306
Mezi Mlaty	VS08	1372	414,4	500,00	0,829
Zahradní	VS10	1180-81	555,9	1 260,04	0,441
Zahradní	VS10	1182-83	307,3	1 260,04	0,244
Zahradní	VS10	1184-85	510,7	1 260,04	0,405
Zahradní	VS10	1186-87	321,0	1 260,04	0,255
			<b>1 694,9</b>	<b>5 040,16</b>	<b>0,336</b>
Lidická 1	VS11/1	530	142,6	310,40	0,460
	VS11/1	531	113,0	245,80	0,460
	VS11/1	532	115,8	256,70	0,451
	VS11/1	533	114,2	253,00	0,451
			<b>485,6</b>	<b>1 065,90</b>	<b>0,456</b>
Lidická 2	VS11/2	534-535	277,9	554,10	0,502
	VS11/2	537	86,0	124,90	0,689
			<b>363,9</b>	<b>679,00</b>	<b>0,536</b>
Lidická 3	VS11/3	539	56,8	77,50	0,733
	VS11/3	540	126,0	313,10	0,402
	VS11/3	541	128,9	320,40	0,402
			<b>311,7</b>	<b>711,00</b>	<b>0,438</b>
Lidická 4	VS11/4	983,984	213,8	620,64	0,344
	VS11/4	982	82,2	77,58	1,059
			<b>295,9</b>	<b>698,22</b>	<b>0,424</b>
Pod Kohoutkem	VS12	975-977	356,4	313,00	1,139
ZUŠ Jungmannova	VS16	byt č. 1	14,8	86,42	0,171

	VS16	byt č. 2	13,8	81,27	0,170
	VS16	byt č. 3	23,4	81,11	0,288
	VS16	byt č. 4	23,9	69,31	0,345
U Vodojemu	VS42	1259	376,1	1 936,17	0,194
	VS42	1279-80	393,8	1 347,64	0,292
	VS42	1278	322,0	625,68	0,515
			<b>1 091,900</b>	<b>3 909,49</b>	<b>0,279</b>
U Vodojemu	VS43	1273	357,9	967,77	0,370
	VS43	1274	223,7	967,77	0,231
	VS43	1275-7	587,8	1 251,36	0,470
	VS43	1277	310,9	625,68	0,497
	VS43	1288-89	488,4	1 154,80	0,423
			<b>1 968,7</b>	<b>4 967,38</b>	<b>0,396</b>
U Vodojemu	VS44	1284-5	298,7	1 154,80	0,259
	VS44	1269	216,9	967,77	0,224
			<b>515,6</b>	<b>2 122,57</b>	<b>0,243</b>
U Vodojemu	VS45	1262-63	422,0	1 154,80	0,365
	VS45	1264-65	288,8	1 154,80	0,250
	VS45	1266-67	378,8	1 154,80	0,328
			<b>1 089,6</b>	<b>3 464,40</b>	<b>0,315</b>
U Vodojemu	VS46	1270	336,7	967,77	0,348
	VS46	1271	274,8	967,77	0,284
	VS46	1272	339,9	967,77	0,351
	VS46	1286-87	307,1	1 154,80	0,266
			<b>1 258,5</b>	<b>4 058,11</b>	<b>0,310</b>
U Vodojemu	VS47	1253-58	285,3	1 218,41	0,234
	VS47	1255-56	300,8	1 218,40	0,247
	VS47	1257	162,0	609,20	0,266
	VS47	1258	162,0	609,20	0,266
			<b>910,0</b>	<b>3 655,21</b>	<b>0,249</b>